

TEST REPORT

Work Location:	Lucideon UK
Purchase Order No.:	361614
Report Date:	20 December, 2016
Author(s):	Mr Dave Boon
For the Attention of:	Mr Danny Hull
Client:	FH Brundle Unit 6, Dorset Road Saltley Business Park Saltley Birmingham B8 1BG
Project Title:	Load Testing of FH Brundle Marano System, Comprising of 2 Uprights with Side Fixing Detail, Handrail and 10 mm Thick Toughened Glass, to BS 6180:2011
Lucideon Reference:	163112 (QT40025/1/SL)/Ref. 3

Mr Dave Dix Consultancy Team Reviewer

Dol Ban

Mr Dave Boon Consultancy Team Project Manager

This report is issued in accordance with the Conditions of Business of Lucideon Limited and relates only to the sample(s) tester. No responsibility is taken for the accuracy of the sampling unless this is done under our own supervision. This report shall not be reproduced in part without the written approval of Lucideon Limited, nor used in any way as to lead to misrepresentation of the results or their implications.

Lucideon Limited Queens Road, Penkhull Stoke-on-Trent Staffordshire ST4 7LQ Page 1 of 8 Pages T +44 (0)1782 764428

enquiries@lucideon.com www.lucideon.com

Lucideon is the trading name of Lucideon Limited. Registered in England No. 1960455.

Test Report: 163112/Ref. 3

CONTENTS

		Page		
1	INTRODUCTION	3		
2	SAMPLES RECEIVED	3		
3	TEST METHOD	3		
4	RESULTS	3		
TA	BLES	5-6		
PLATE		7		
Cł	CHART			
AF	APPENDIX A – Drawing			

Lucideon Limited were commissioned by the client, FH Brundle to carry out load testing in accordance with BS 6180:2011 Barriers in and about buildings, and EC1-1991-1-1:2002 UK National Annex to Eurocode 1: Actions on structures – Part 1-1: General actions - Densities, self-weight, imposed loads for buildings. This will allow their balustrade system to be classified for use in accordance with the Code of Practice included within the standard.

The system tested was referred to as Marano consisting of posts, handrail and toughened glass panel.

The testing was carried out at the Lucideon Laboratories located in Queens Road, Stoke-on-Trent.

This report summarises the test result obtained during the test and does not provide interpretation of those results.

2 SAMPLES RECEIVED

2 Posts nominally 1350 mm tall (including base thickness) and manufactured from 50 mm x 50 mm square aluminium.

Shuffle glazed with 10 mm toughened safety glass and fitted with an oval aluminium top rail.

Posts set at 1200 mm centres.

1 box of Fischer 040950 FBN II 12 X 105 Zinc Plated Fixings.

The Marano system is shown in the Figure in the Appendix.

3 TEST METHOD

The 2 posts were bolted to the side of a concrete substrate at 1200 mm centres.

Plate 2 shows the load arrangement.

A horizontal imposed line load was applied to the handrail at a height of 1.1 m above the datum level of the floor and the deflection measured at the top central point of the handrail 1.1 m above the datum level of the floor. The load was applied via a hydraulic ram and the deflection measured using a digital electronic displacement transducer (see Plate 1).

4 RESULTS

The tests were carried out in accordance with the guidance given in BS 6180 Barriers in and about buildings – Code of Practice. The standard states that the maximum allowable deflection for a free standing glass protective barrier panel is 25 mm.

Table 2 of BS 6180 Barriers in and about buildings – Code of Practice categorises parapets, barriers and balustrades for areas of use depending on the loads they have achieved under testing.

The load versus deflection curve for the FH Brundle Marano system with the load applied as a line load across the top handrail is shown in Chart 1.

The loads achieved by the FH Brundle Marano system under horizontal imposed line load to the maximum deflection of 25 mm is given in Table 1.

All figures quoted in the Tables contain no safety factors and are direct loads as achieved by the system under test conditions.

Tables 2 and 3 summarise the suitability of the tested systems in accordance with Table 2 of BS 6180:2011.

NOTE: The results given in this report apply only to the samples that have been tested.

END OF REPORT

TABLES

Table 1 - Summary of Performance of FH Brundle Marano System with L oad Applied to Top Rail at 1200 mm Post Centres, Side Fixed

	Imposed Line	Expected Working	Deflection at	Achieved
Detail	Load at 25 mm	Line Load for	Working Line Load	Classification
	Deflection (kN/m)	System (kN/m)	for System (mm)	(kN/m)
Marano System side fixed				
with 10 mm toughened glass	1.17	0.74	15.67	0.74
and handrail				

Table 2 - Summary of Suitability of FH Brundle Marano System with Load Applied to Top Rail, at 1200 mm Post Centres , Side Fixed

Type of Occupancy for Part of the Building	Type of cupancy for Examples of Specific Use of the Building		Marano System (Side Fixed)
Domestic and	(i) all areas within or serving exclusively one single family dwelling including stairs, landings, etc. but excluding external balconies and edges of roofs	0.36	
residential activities	(ii) other residential, i.e. houses of multiple occupancy and balconies, including Juliette balconies and edges of roofs in single family dwellings	0.74	
Offices and work	(iii) light access stairs and gangways not more than 600 mm wide	0.36	
areas not included	(iv) light pedestrian traffic routes in industrial and storage buildings except designated escape routes	0.36	
storage areas	(v) areas not susceptible to overcrowding in office and institutional buildings, also industrial and storage buildings except as given above	0.74	
Areas where people might congregate	(vi) areas having fixed seating within 530 mm of the barrier, balustrade or parapet	1.50	x
Areas with tables or fixed seating	(vii) restaurants and bars	1.50	x

Table 2 (Continued)

Type of Occupancy for Part of the Building	Examples of Specific Use	Horizontal Uniformly Distributed Line Load (kN/m)	Marano System (Side Fixed)
Areas without	(viii) stairs, landings corridors ramps	0.74	
obstacles for moving people and not susceptible to overcrowding	(ix) external balconies including Juliette balconies and edges of roofs; footways and pavements within building cartilage adjacent to basement/sunken areas	0.74	
	(x) footways or pavements less than 3 m wide adjacent to sunken areas	1.50	х
Areas susceptible to overcrowding	(xi) theatres, cinemas, discotheques, bars, auditoria, shopping malls, assembly areas, studios; footways or pavements greater than 3 m wide adjacent to sunken areas	3.00	х
	(xii) grandstands and stadia	(Note A)	-
Retail areas	(xiii) all retail areas including public areas of banks/building societies or betting shops	1.50	x
Vehicular	(xiv) pedestrian areas in car parks, including stairs, landings, ramps, edges of internal floors, footways, edges of roofs	(Note B)	Х
	(xv) horizontal loads imposed by vehicles	(Note B)	-

Note A - See requirements of the appropriate certifying authority. Note B – See Appendix A of BS 6180:2011.

Test Report: 163112/Ref. 3

PLATE



Plate 1 - Test Arrangement

Test Report: 163112/Ref. 3



Chart 1 - Load v Deflection for FH Brundle Marano System, Incorporating 2 Posts 1350 mm Tall for Side Fixing, Shuffle Glazed with 10 mm Toughened Safety Glass and Fitted with Oval Aluminium Rail, Line Load Applied 1100 mm from Base of Concrete



Ξ	NOTES: Technical Information Drawing - Not To Be Supplied To Customers			
	DESCRIPTION:			
	Marano - General arra	ngement of tested system		
	PART NO:			
	N/A			
	DWG NO:			
	0001-001-103			A3
	SCALE:1:20	DO NOT SCALE DRAWING	SHEET	1 OF 1